



# AS 5637.1-2015 FIRE RATING STATEMENT

August 2023

## ARLON

Arlon Graphics declare that the graphic films we supply have been tested for Surface Burning Characteristics of Building Materials in accordance with the procedure outlined in AS/NZS 3837-1998 Method.

This applies to the following products:

Product Name	NCC Group Number	Smoke Growth Rate (sqm/kg)
<b>Digital Print Film (DPF)</b>		
DPF 4200 Matte	1	68.2
DPF 4200 Canvas	1	32.5
DPF 4600GLX	1	46.1
DPF 4650GLX	1	26.0
DPF 8200 High Tack	1	52.2
<b>Overlaminates Series</b>		
Series 3460G	1	27.9
Series 3460M	1	32.3

Arlon declares that no formula changes which have impact on tested properties have been made to any of the mentioned products during the period between testing and present. There is also no distinction between colors of tested film.

Prepared by:

Chi Chan  
Tech Service Engineer  
Arlon Graphics, LLC.



### USA

**a** 200 Boysenberry Lane, Placentia, CA 92870  
**p** 800 232 7161 / +1 714 985 6300  
**f** +1 714 985 6305

### EUROPE

**a** Dr. Lelykade 22B, 2583CM Den Haag, The Netherlands  
**p** +31 70 354 4311  
**f** +31 70 355 7721

### CHINA

**a** No. 1989 Xinchang Road, Weifang, Shandong, 262400  
**p** +86 0536 6226568